

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2020337
Permit #: 01173-2025UPG
Request Rec'd: 09/05/2025
Approval Date:09/08/2025 DS
Permit Expires: 03/10/2026

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

J. N. Mini Mart, Inc. 1343 South Lewis Avenue Waukegan, IL 60085 Lake County

Contact: Jaswinder Singh 847/249-1257

**FACILITY** 

- name and address where tanks are located:

J. N. Mini Mart (Clark) 1343 South Lewis Avenue Waukegan, IL 60085 Lake County

Contact: Nazar Singh 847/249-1257

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	12,000	Currently in use	Federal

## **Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

### **Summary of Work**

T4 RUL ball float fails testing. Replacing ball float with drop tube. Drop tube seized in spill bucket, replacing spill bucket.

## **Special Contingencies**

Vaniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: trevorh@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026			

Sincerely,

**Daniel Starks**