



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2039516
Permit #: 01174-2025REM
Request Rec'd: 09/07/2025
Approval Date: 09/08/2025 SK
Permit Expires: 03/10/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 509 Petroleum, Inc. 5901 S. Ashland Chicago, IL 60636 Cook County Contact: Ali Salem 773/434-8870	FACILITY - name and address where tanks are located: Citgo 5901 S Ashland Chicago, IL 60636 Cook County Contact: Ali Salem 773/434-8870
---	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	6,000	Gasoline - Premium	
2	5,000	Diesel Fuel	
3	12,000	Gasoline - Regular	

Summary of Work

Removing the existing flexible piping at this location and replacing with new Nupi DW Semi-Rigid piping under separate Upgrade permit.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 3/8/2027

Sincerely,

Sean Keane