



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2010054
Permit #: 00969-2025UPG
Request Rec'd: 07/25/2025
Approval Date: 07/28/2025 SB
Amended Date: 09/08/2025 DS
Permit Expires: 01/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Jagtar Singh 750 Glenwood Dryer Road Glenwood, IL 60425 Cook County Contact: Balwinder Kaur 773/671-9502 | FACILITY - name and address where tanks are located: Citgo 750 Glenwood Dryer Road Glenwood, IL 60425 Cook County Contact: Balwinder Kaur 773/671-9502 |
|--|---|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4 | Gasoline - Regular | 8,000 | Currently in use | Federal |
| 5 | Gasoline - Premium | 8,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|--|---|
| Piping | Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping | Replacing - Piping - Fiberglass Double Wall |
| Piping | Shear Valves | New |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|--|---|
| Piping | Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping | Replacing - Piping - Fiberglass Double Wall |
| Piping | Shear Valves | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 1/2 | Sump / Sensors Changing |
| 7/8 | New |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| 🔌 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Summary of Work

Adding a fourth dispenser by cutting into existing double wall fiberglass pipe, extending 10' and installing a new under dispenser containment sump. Pipe will carry thru the UDC and connect to existing piping on the other side to feed the two dispensers along Glenwood-Dyer Road. We will add a Veeder-Root 794380-208 sensor with positive shut down.

Special Contingencies**Amendment Reason:**

Moving an existing fueling position 4' from its current position which will require cutting and adding pipe.

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: DJ White
Phone: 708/474-3344
Email: jim.veverka@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Shelly Bradley

For Office Use Only**Dispenser 1/2 Equipment**

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
|----------------|------------------|--------|