



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 3033082
Permit #: 01024-2025UPG
Request Rec'd: 08/06/2025
Approval Date: 08/07/2025 DS
Amended Date: 09/09/2025 DS
Permit Expires: 02/09/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Kress Enterprises Inc Po Box 241 227 Illinois St Brimfield, IL 61517 Peoria County Contact: Rich Meredith 309/446-3395	FACILITY - name and address where tanks are located: Kress Enterprises Inc Greater Peoria Airport Peoria, IL 61607 Peoria County Contact: Grant Abenroth 309/446-3395
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Jet A	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

replace Tank 1 spill bucket with a new DW spill bucket. Remove the overfill drop tube valve as a form of overfill protection, overfill alarm will be the form of protection

Amending this permit because i forgot to add the new Tank 1 DW spill bucket when i originally did the permit.

Special Contingencies

Amendment Reason:

Forget to add the new DW spill bucket for tank 1 when we orianally did this permit.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/202-0792 Email: amannino@iome.com Contractor License # IL1293 Exp. 2/4/2026

Sincerely,

Daniel Starks