



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2039516
Permit #: 01194-2025INS
Request Rec'd: 09/07/2025
Approval Date: 09/11/2025 SK
Permit Expires: 03/11/2026

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: 509 Petroleum, Inc. 5901 S. Ashland Chicago, IL 60636 Cook County Contact: Ali Salem 773/434-8870 | FACILITY - name and address where tanks are located: Citgo 5901 S Ashland Chicago, IL 60636 Cook County Contact: Ali Salem 773/434-8870 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|---------|----------|--------------------|------------------|
| 4 | E85 | 5,000 | Tank Not Installed | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Jacketed Steel Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Flexible Double Wall NUPI Smartflex | New |
| Piping | Other Submersible Pump | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Jacketed Steel Double Wall | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-----------------|
| 1/2 | Replacing - 1/2 |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.

There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

We will be installing (1) Modern Welding Glassteel II DW tank for E85 as shown on plan. We will be installing a 42" SWFRP STP Sump, compatible FE Petro AG series STP, Nupi Smartflex DW piping, and SW Dispenser Sump along with compatible Shear Valve (disp #1/2). We will also be installing a new VR TLS 450 Plus console and VR position sensitive liquid sensors at all sumps with positive shutdown.

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|---|
| Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191 | Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2026 |

Sincerely,

Sean Keane

For Office Use Only

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |