



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-020795
Permit # 01776-2006ENT
Request Rec'd 11/21/2006
Amended Date
Approval Date 11/21/2006 JC
Permit Expires 5/21/2007

Permit for ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois Ayers Oil Company Rt. I-72 & 24, P. O. Box 772, Hwy 24 & 336 Junction Quincy, IL 62301 Contact: Carl Adams Jr (217) 434-8662	(2) FACILITY - name and address where tanks are located: Ayerco Convenience Ctr #11 220 W Washington St Pittsfield, Pike Co., IL Contact: Carl Adams Jr Carl (217) 434-8662
---	--

(3) ENTRY OF TANKS:

- (a) Number and size of tanks being entered:* (TK # 5) - 12,000 gallons
- (b) Type of tanks:*
- (c) Product stored in each tank:* (TK # 5) - Gasoline
- (d) Reason for tanks being entered:*
- (e) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Contractor will remove the manway cover to allow the factory inspector to visually inspect the inner tank. Xerxes Corp. will be on site 11/28/06 to check out the tank to see why it failed. No person will enter tank on this date. The Storage Tank Safety Specialist must be scheduled to be on site when the tanks are penetrated.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Phone: Contractor Registration # Exp.

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)