



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY
Facility #: 7023255
Permit #: 01195-2025REM
Request Rec'd: 09/11/2025
Approval Date: 09/11/2025 DS
Revision Date: 09/16/2025 DS
Permit Expires: 03/11/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ekansh, Inc. 200 N. Front Street Cobden, IL 62920 Union County Contact: Vikram Patel 606/407-1853	FACILITY - name and address where tanks are located: Ekansh, Inc. 200 N. Front Street Cobden, IL 62920 Union County Contact: Sweta Patel 606/407-1853
---	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	2,000	Gasoline	
2	2,000	Diesel Fuel	11/29/2023
3	1,000	Kerosene	06/26/2007
4	10,000	Gasoline - Regular	11/29/2023

Summary of Work

remove the piping and vent lines

Special Contingencies

Revision Reason:

Added tanks 1 and 3 as the previously abandoned piping for these tanks will be removed as well.

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Perry Environmental, Inc. 900 South Spring Street Springfield, IL 62704	Contact Person: julie keebler Phone: 217/523-5446 Email: mkeebler@perryenvironmental.net Contractor License # IL002445 Exp. 4/6/2026

Sincerely,

Daniel J. Starks

Daniel Starks