



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3026528
Permit #: 01207-2025UPG
Request Rec'd: 09/16/2025
Approval Date: 09/16/2025 DS
Permit Expires: 09/29/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: AM PM 125, Inc. 1012 E. Broadway P.O. Box 855 Astoria, IL 61501 (None) County Contact: Gopal Basnet 217/306-2920 | FACILITY - name and address where tanks are located: AM PM 125, Inc. 1012 East Broadway P.O. Box 93 Astoria, IL 61501 Fulton County Contact: Everest Thapa 512/818-7199 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2 | Gasoline - Premium | 4,000 | Currently in use | Federal |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|--------------------------|--------|
| Piping | Steel Single Wall Piping | New |

Summary of Work

REMOVED THE FIBERGLASS VENT FROM TANK .
INSTALL NEW 2" STEEL RISER ON TOP OF TANK. PIPING IS LOCATION IN THE AREA BEHIND THE FENCE NO TRAFFIC.

Special Contingencies

| | |
|--|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305 | Contact Person: Marty Jackson Phone: 217/223-2190 Email: kmajors@rlhoener.com Contractor License # IL2021 Exp. 5/22/2026 |

Sincerely,

Daniel Starks