



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1015027  
Permit #: 01212-2025UPG  
Request Rec'd: 09/17/2025  
Approval Date: 09/17/2025 DS  
Permit Expires: 03/17/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Winnebago County Contact: Debbie Viederis 815/387-6243	<b>FACILITY</b> - name and address where tanks are located: Byron Mobil 100 South Union Street Byron, IL 61010 Ogle County Contact: Jessi Mulrooney 815/397-9410
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
12	Gasoline - Regular	12,000	Currently in use	Federal
13	Gasoline - Mid-grade	8,000	Currently in use	Federal

**Tank 12 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

**Tank 13 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

**Summary of Work**

Replacing existing tank top sumps and submersible pumps on the regular and midgrade

**Special Contingencies**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Oil Equipment Company, Inc.  
4701 Lien Road  
Madison, WI 53704

Contact Person: TJ Winkler  
Phone: 608/354-1992  
Email: msobczak@oilequipment.com  
Contractor License # IL1318 Exp. 11/13/2026

Sincerely,



---

Daniel Starks