

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 1038981
Permit #: 01220-2025UPG
Request Rec'd: 09/18/2025
Approval Date:09/18/2025 DS
Permit Expires: 03/18/2026

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County

Contact: Joey Cupp 865/588-7488

FACILITY

LaSalle County

- name and address where tanks are located:

Flying J Travel Plaza #644 343 Civic Road La Salle, IL 61301

Contact: Rani Baily 815/220-0611

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4 | Gasoline - Regular | 20,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
| Piping | Shear Valves | New |

Summary of Work

REPLACING RUL SHEAR VALVE AT DISP 1,2

Special Contingencies

NOTE: UDC must be installed if not already existing

PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.

5060 Arsenal Street St. Louis, MO 63139

Caniel J. Starke

Contact Person: Jimmy Spiros

Phone: 314/772-4501

Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel Starks