



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2010054  
Permit #: 00969-2025UPG  
Request Rec'd: 07/25/2025  
Approval Date: 07/28/2025 SB  
Amended Date: 09/19/2025 DS  
Permit Expires: 01/28/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Chicago Title Land Trust Co. Trust No. 18172 750 E. Glenwood Dryer Rd. Glenwood, IL 60425 Cook County Contact: Balwinder Kaur 773/671-9502	<b>FACILITY</b> - name and address where tanks are located: Preet Retail, Inc. / Shell 750 E. Glenwood Dryer Rd. Glenwood, IL 60425 Cook County Contact: Balwinder Kaur 773/671-9502
--	--

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	8,000	Currently in use	Federal
5	Gasoline - Premium	8,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron	Replacing - Piping - Fiberglass Double Wall
Piping	Shear Valves	New

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron	Replacing - Piping - Fiberglass Double Wall
Piping	Shear Valves	New

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing
7/8	New

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Summary of Work

Adding a fourth dispenser by cutting into existing double wall fiberglass pipe, extending 10' and installing a new under dispenser containment sump. Pipe will carry thru the UDC and connect to existing piping on the other side to feed the two dispensers along Glenwood-Dyer Road. We will add a Veeder-Root 794380-208 sensor with positive shut down.

### Special Contingencies

**NOTE: Dispensers must be a full 10' from buildings and property lines.**

### Amendment Reason #1:

Moving an existing fueling position 4' from its current position which will require cutting and adding pipe.

### Amendment Reason #2:

Existing dbl wall fiberglass pipe is not Smith Red-Thread fiberglass as originally noted on permit application. Inspector Lehnert wanted the permit amended to show existing pipe is actually dbl wall Ameron fiberglass.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: jim.veverka@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Shelly Bradley

### For Office Use Only

#### Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

#### Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------