



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 1040284
Permit #: 01218-2025UPG
Request Rec'd: 09/18/2025
Approval Date: 09/18/2025 DS
Amended Date: 09/19/2025 DS
Permit Expires: 03/18/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: GPM Midwest, LLC 8565 Magellan Pkwy, Ste. 400 Richmond, VA 23227 (None) County Contact: Rolfe Lann 804/730-1568	FACILITY - name and address where tanks are located: Fas Mart #5222 3302 S. 11th Street Rockford, IL 61109 Winnebago County Contact: Jonnie Mitchell 804/730-1568
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	8,000	Currently in use	Federal
2	Gasoline - Regular	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Flexible Double Wall OPW Pisces

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Flexible Double Wall OPW Pisces
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Summary of Work

Replacing RUL and PUL lines between tank and dispensers 1/2, 3/4. Replacing RUL tank sump only. Existing UDCs to remain.

Special Contingencies

Amendment Reason:

Customer adding replacement of PUL line between tank and dispensers 1/2, 3/4.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 815/398-6250
Email: trevorh@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks