



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7036383
Permit #: 01237-2025CAT
Request Rec'd: 09/21/2025
Approval Date: 09/22/2025 DS
Permit Expires: 03/24/2026

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Casey's General Stores #2053 202 S. Park Street Sesser, IL 62884 Franklin County Contact: John Kearby 618/625-3034
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Removing Cathodic Protection after contractor has made containments water tight/dry

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Midwest Tank Testing, LLC 2008 Medical Center Dr Monticello, IL 61856	Contact Person: Stephen T. Hall Phone: 217/714-4305 Email: midwesttanktestingsth@aol.com Contractor License # IL002461 Exp. 1/2/2026

Sincerely,

Daniel J. Starks

Daniel Starks