



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2014604
Permit #: 01243-2025REM
Request Rec'd: 09/18/2025
Approval Date: 09/23/2025 DS
Permit Expires: 03/24/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 3005 Kirchoff, LLC 7105 N. Keating Lincolnwood, IL 60712 (None) County Contact: Faris Saleh 773/920-8379	FACILITY - name and address where tanks are located: 3005 Kirchoff, LLC 3005 Kirchoff Road Rolling Meadows, IL 60008 Cook County Contact: Faris Saleh 773/920-8379
--	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	10,000	Gasoline - Regular	
2	10,000	Gasoline - Regular	
3	10,000	Gasoline - Premium	
4	6,000	Gasoline - Premium	
5	6,000	Diesel Fuel	

Summary of Work

Removing all islands and underground supply piping as part of a station rebuild project.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: jim.veverka@bkequip.com Contractor License # IL1207 Exp. 12/17/2025

Sincerely,

Daniel Starks