



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2040688
Permit #: 01253-2025UPG
Request Rec'd: 09/23/2025
Approval Date: 09/23/2025 DS
Permit Expires: 03/24/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Costco Wholesale Corporation P.O. Box 35005 Seattle, WA 98124 (None) County Contact: Jay Grubb 425/251-6222 | FACILITY - name and address where tanks are located: Costco Fueling Facility #371 505 W. Army Trail Road Bloomington, IL 60453 Du Page County Contact: Ross Sloma 630/893-4558 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 20,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|--------------------------|--------|
| Piping | Extractor Fitting Valves | New |

Summary of Work

TANK# 1 Regular = Removing existing extractor fitting / galvanized fittings that are rusted out and have holes in them and installing new for the Vent line inside the sump

Special Contingencies

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448 | Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2026 |

Sincerely,

Daniel Starks