



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2000890
Permit #: 00836-2025UPG
Request Rec'd: 07/02/2025
Approval Date: 07/07/2025 DS
Amended Date: 09/25/2025 DS
Permit Expires: 01/07/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: TNC Gas Company, Inc. 17002 Torrence Ave. Lansing, IL 60438 Cook County Contact: Justin Jose 847/287-5125	FACILITY - name and address where tanks are located: TNC Gas Company, Inc. 17002 Torrence Ave. Lansing, IL 60438 Cook County Contact: Justin Jose 847/287-5125
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Out of service	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

Dispensers on the Permit

Dispenser	Action
5/6	Sump / Sensors Changing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Summary of Work

We are installing a single wall UDC on dispenser 5/6 as there was leak reported by testing and at the same time we fixing shear valve height on dispenser 9/10 by re doing the for compliance

Special Contingencies

Amendment Reason:

Adding the Tanks missing

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2027

Sincerely,

Daniel J. Starks

Daniel Starks

For Office Use Only

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing