



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 6018498
Permit #: 01089-2025UPG
Request Rec'd: 08/20/2025
Approval Date: 08/20/2025 DS
Amended Date: 09/29/2025 DS
Permit Expires: 02/20/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County Contact: Joey Cupp 865/588-7488	FACILITY - name and address where tanks are located: Pilot Travel Center #249 820 Edwardsville Road Troy, IL 62294 Madison County Contact: Pat Heinkebein 618/667-0946
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Diesel Fuel	20,000	Currently in use	Federal
10	Gasoline - Regular	12,000	Currently in use	Federal
11	Gasoline - Regular	6,000	Currently in use	Federal
12	Gasoline - Premium	6,000	Currently in use	Federal
14	Diesel Fuel	20,000	Currently in use	Federal
15	B-99	20,000	Currently in use	Federal

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Leak Detection - Tank	SIR and Prec Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D	New

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Leak Detection - Tank	SIR and Prec Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D	New
Leak Detection - Tank	Vacuum Veeder Root Secondary Containment Vacuum Sensing System (Tank)	Replacing - Leak Detect - Tank - Vacuum Gauge

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Leak Detection - Tank	SIR and Prec Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D	New
Leak Detection - Tank	Vacuum Veeder Root Secondary Containment Vacuum Sensing System (Tank)	Replacing - Leak Detect - Tank - Vacuum Gauge

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Leak Detection - Tank	SIR and Prec Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D	New
Leak Detection - Tank	Vacuum Veeder Root Secondary Containment Vacuum Sensing System (Tank)	Replacing - Leak Detect - Tank - Vacuum Gauge

Tank 14 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Leak Detection - Tank	SIR and Prec Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D	New

Tank 15 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Leak Detection - Tank	SIR and Prec Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D	New

Summary of Work

UPGRADING SITE TO TLS 450 PLUS AND WARREN ROGERS SIR.

TANK 10 TO INCLUDE VACUUM SENSOR.

amended to include tanks 11 and 12 vacuum veeder root secondary containment

Special Contingencies**Amendment Reason:**

amend permit to include tanks 11 and 12 vacuum veeder root secondary containment system

PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: 314/772-4501
Email: testing@neumayerequipment.com
Contractor License # IL1502 Exp. 3/26/2026

Sincerely,



Daniel Starks