



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3020801
Permit #: 01278-2025CAT
Request Rec'd: 09/30/2025
Approval Date: 09/30/2025 DS
Permit Expires: 03/31/2026

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sumbal Corporation 705 W. Clinton Street Rushville, IL 62681 Schuyler County Contact: Ahmed Nasir 217/770-4046	FACILITY - name and address where tanks are located: MNA Food Mart 1672 N. Henderson Galesburg, IL 61401 Knox County Contact: Rachel Collins 217/770-4046
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Mid-grade	12,000	Currently in use	Federal
3	Gasoline - Premium	8,000	Currently in use	Federal
4	Diesel Fuel	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Disp 9/10	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp 9/10
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 11/12	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 11/12

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 11/12	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 11/12
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 9/10	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 9/10

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 11/12	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 11/12
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 9/10	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 9/10

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 13/14	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 13/14
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - Dispenser 15/16	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Dispenser 15/16

NACE Certified Designer**NACE Certified Designer Number****Method of Integrity Assessment of Tanks****Special Contingencies****Summary of Work**

Reinstalling/Replacing CP on UDC Flex's per NOV

PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest Tank Testing, LLC
2008 Medical Center Dr
Monticello, IL 61856

Contact Person: Stephen T. Hall
Phone: 217/714-4305
Email: midwesttanktestingsth@aol.com
Contractor License # IL002461 Exp. 1/2/2026

Sincerely,



Daniel Starks