



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7002136
Permit #: 01292-2025CAT
Request Rec'd: 10/03/2025
Approval Date: 10/03/2025 DS
Permit Expires: 04/03/2026

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Chuck Wagon Charlie's, Inc. 2210 County Road 150N Barnhill, IL 62809 Wayne County Contact: Travis Vaughan 618/516-2340	FACILITY - name and address where tanks are located: Chuck Wagon Charlie's Inc. 746 County Road 2550 North Burnt Prairie, IL 62820 White County Contact: Crystal Vaughan 618/516-2340
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	10,000	Currently in use	Federal
5	Diesel Fuel	6,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

A CP design by NACE Engineer #3384 Jeff Harris with Corrosion Concerns has provided a design to install sacrificial anodes to the flex connector piping in the facility's unleaded and diesel STP containment sumps to provide corrosion protection. Test prior to installation taking native potentials then install 1 5lb anode per containment attached to the steel flex piping and perform testing. A re-survey will be performed 6 months ater install to ensure the anodes are working properly. All documents and testing will be submitted to the ILSFMO office. Please see attached CP Design

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: 812/425-4137 Email: compliance@hci4.com Contractor License # IL646 Exp. 7/3/2026

Sincerely,

Daniel J. Starks

Daniel Starks