



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2035951
Permit #: 01314-2025UPG
Request Rec'd: 10/08/2025
Approval Date: 10/08/2025 DS
Permit Expires: 04/08/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Penske Truck Leasing Co., LP Route 10 Green Hills Reading, PA 19603 Contact: Morgan McCusker 610/775-6409	FACILITY - name and address where tanks are located: Penske Truck Leasing 1222 Naperville Road Romeoville, IL 60446 Will County Contact: Morgan McCusker 610/775-6409
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Out of service	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD

Summary of Work

Replacing the TLS 350 with new TLS 450 Plus, changing existing sensors to smart sensors.

Special Contingencies

NOTE: There is an N.O.V. for the overfill prevention for tank #1. That work MUST be done at or before the time of this permitted work.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel J. Starks

Daniel Starks