



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2027927
Permit #: 01323-2025UPG
Request Rec'd: 10/09/2025
Approval Date: 10/09/2025 DS
Permit Expires: 04/09/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Penske Truck Leasing Co., LP Route 10 Green Hills Reading, PA 19603 Contact: Morgan McCusker 610/775-6409	FACILITY - name and address where tanks are located: Penske Truck Leasing Company, L.P. 3061 Washington Street Waukegan, IL 60085 Lake County Contact: Jack Sojer 847/623-3074
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	15,000	Currently in use	Federal
2	Gasoline - Regular	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD

Summary of Work

We are replacing new TLS 450 Plus, replacing DPLLD's.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel J. Starks

Daniel Starks