

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

Replacement of 01182-2025UPG

FOR OFFICE USE ONLY

Facility #: 1040639
Permit #: 01331-2025UPG
Request Rec'd: 10/09/2025
Approval Date:10/09/2025 DS
Permit Expires: 10/21/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Woodman's Food Market, Inc. 2631 Liberty Lane Janesville, WI 535450741 (None) County

Contact: Deb Arnold 608/754-8382

**FACILITY** 

- name and address where tanks are located:

Woodman's Store #30 3205 McFarland Rd. Rockford, IL 61114 Winnebago County

Contact: Jacob Bishop 608/754-8382

#### **Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1      | Gasoline - Regular | 12,000   | Currently in use | Federal          |

### Tank 1 Equipment

| Equipment Type | Permit Equipment     | Action |
|----------------|----------------------|--------|
| Piping         | Flex Connector Steel | New    |

#### **Summary of Work**

Replace leaking flex connector in REG STP

# **Special Contingencies**

## Replacement Reason:

Missed the notice & timeframe to have a final after 10 days.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group

Janiel J. Starke

2422 Center Street Rockford, IL 61108 Contact Person: Robert Stenstrom

Phone: 815/398-6250

Email: amberp@rstenstrom.com

Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks