

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3001815
Permit #: 01337-2025UPG
Request Rec'd: 10/13/2025
Approval Date:10/14/2025 DS
Permit Expires: 04/14/2026

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS- Corporation, partnership, or other business entity:

7-Eleven, Inc. 3200 Hackberry Road - Gas Compliance Irving, TX 75063 (None) County

Contact: Zachary Davis 937/203-7827

FACILITY

- name and address where tanks are located:

7-Eleven #34455 1636 38th Street Rock Island, IL 61201 Rock Island County

Contact: Stephanie Anthony 309/793-0043

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	8,200	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

Summary of Work

Diesel Spill failed comliance testing. Replaced it and the overfill valve with new Franklin Fueling.

Special Contingencies

Janiel J. Starky

PERSON, FIRM OR COMPANY PERFORMING WORK:

Pipeco, Inc.
610 29th Street
Bettendorf, IA 52722

Contact Person: Robert Schafer
Phone: 563/344-0700
Email: rob@pipecoinc.com
Contractor License # IL2034 Exp. 9/28/2026

Sincerely,

Daniel Starks