



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022339
Permit #: 01354-2025UPG
Request Rec'd: 10/10/2025
Approval Date: 10/14/2025 SK
Permit Expires: 04/14/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 3000 West 63rd Chicago LLC 26 Mill Plain Road Danbury, CT 06811 (None) County Contact: Syed Kirmni 845/765-8507	FACILITY - name and address where tanks are located: SNK Fuels 3000 W. 63rd Street Chicago, IL 60629 Cook County Contact: Syed Kirmani 845/765-8507
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	9,000	Currently in use	Federal
6	Gasoline - Regular	3,000	Currently in use	Federal
7	Gasoline - Premium	3,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall
Piping	Shear Valves	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall
Piping	Shear Valves	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
🔌 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall
Piping	Shear Valves	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
🔌 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replace product piping with new sumps positive shutdown sensors will be instaled.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

CAT Builders USA, Inc.
522 E. Dundee Road
Palatine, IL 60074

Contact Person: Jan kopytek
Phone: 630/670-6280
Email: Jankopytek@gmail.com
Contractor License # IL002381 Exp. 5/9/2026

Sincerely,

Sean Keane

For Office Use Only

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing