



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4037518
Permit #: 01355-2025ABN
Request Rec'd: 10/14/2025
Approval Date: 10/14/2025 DS
Permit Expires: 04/14/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: De Witt County Building 201 West Washington Clinton, IL 61727 Dewitt County Contact: Kevin Kemp 217/935-3782	FACILITY - name and address where tanks are located: De Witt County Building 201 West Washington Clinton, IL 61727 Dewitt County Contact: Kevin Kemp 217/935-3782
--	--

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
2	2,000	Diesel Fuel	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Owner contacted OSFM and it was suggested to abandon in place due to close proximity to the building and the existing active tank.

Location of Tanks Being Abandoned

Tank is located between a building and an active tank as shown in site plan

Location of Piping Being Abandoned

Piping to be removed under a separate removal permit.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Chase Environmental Group, Inc. 11450 Watterson Court Louisville, KY 40299	Contact Person: Zack Page Phone: 217/971-6120 Email: zpage@chaseenv.com Contractor License # IL2036 Exp. 3/17/2027

Sincerely,

Daniel Starks