

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 5040554
Permit #: 01368-2025UPG
Request Rec'd: 10/16/2025
Approval Date:10/16/2025 DS
Permit Expires: 04/16/2026

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Casey's Retail Company

3305 SE Delaware Ave. P.O. Box 3004

Ankeny, IA 50021

Contact: Lee Lytle 515/446-6231

FACILITY

- name and address where tanks are located:

Casey's General Stores #2332 908 W. Carpenter Street Jerseyville, IL 62052 Jersey County

Contact: Jill Reams Widder 515/965-6238

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 2 | Diesel Fuel | 12,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Piping | Flex Connector Steel | New |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Piping | Flex Connector Steel | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-----------------|
| 1/2 | Replacing - 1/2 |
| 3/4 | Replacing - 3/4 |
| 5/6 | Replacing - 5/6 |
| 7/8 | Replacing - 7/8 |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|------------------|
| Dispenser | Single Wall UDC Sump | Reusing Existing |

Summary of Work

Replacing all four dispensers with new Wayne Ovation fueling dispensers.

Breakout island 1/2, install shorter flex connectors and install a lower height concrete island to meet ADA requirements. Line and leak detector tests.

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | |
|--|---|--|
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 414/491-1002 Email: mikem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026 | |

Sincerely, Daniel J. Starks

Daniel Starks