



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6029218
Permit #: 01371-2025UPG
Request Rec'd: 10/09/2025
Approval Date: 10/16/2025 DS
Permit Expires: 04/16/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Road Ranger, LLC 1501 Woodfield Rd., Suite 300 S Schaumburg, IL 60173 Cook County Contact: John Carabelli 815/387-1700	- name and address where tanks are located: Road Ranger #157 905 Hen House Road Route 177 & I-64 Okawville, IL 62271 Washington County Contact: Ben Talley 815/656-4143

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	20,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P200SC	New
Piping	Single Wall Transition Sump	Replacing - Piping - Single Wall Transition Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Dispensers on the Permit

Dispenser	Action
17	Sump / Sensors Changing
17S/18M	Sump / Sensors Changing
18S/19M	Sump / Sensors Changing
19S/20M	Sump / Sensors Changing
20S	Sump / Sensors Changing

Dispenser 17 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser 17S/18M Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser 18S/19M Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser 19S/20M Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispenser 20S Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Summary of Work

Installing new product piping for diesel dispensers 17 - 20 Satelite. New islands will be installed, new dispenser sumps, and a new transition sump. All existing sump sensors to be reused. The existing canopy will remain.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: tsmith@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

Daniel G. Starks

Daniel Starks