



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2024827
Permit #: 01379-2025UPG
Request Rec'd: 10/13/2025
Approval Date: 10/20/2025 DS
Permit Expires: 04/21/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Cook County Highway Department 8900 W. 135th Street Orland Park, IL 60462 Cook County Contact: Randy Piscitelli 708/388-2134	FACILITY - name and address where tanks are located: Cook County Highway Dept Dist 4 8900 W. 135th Street Orland Park, IL 60426 Cook County Contact: Randy Piscitelli 708/388-2134
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	2,500	Currently in use	Federal
7	Diesel Fuel	10,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor in Single Wall STP/Tanktop Sump	Removing

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor in Single Wall STP/Tanktop Sump	Removing

Summary of Work

Change existing tank sump sensors to non-regulated.
Site is a European suction system and sensors are not needed.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel J. Starks

Daniel Starks