



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

FOR OFFICE USE ONLY	
Facility #:	2042682
Permit #:	01384-2025UPG
Request Rec'd:	10/20/2025
Approval Date:	10/20/2025 DS
Amended Date:	10/21/2025 DS
Permit Expires:	04/21/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: CCTT Petroleum, Inc. 308 Scotts Court Bolingbrook, IL 60440 Du Page County Contact: Chacko Chittalakattu 000/000-0000	<b>FACILITY</b> - name and address where tanks are located: CCTT Petroleum, Inc. 951 E. 162nd Street South Holland, IL 60473 Cook County Contact: Chacko Chittalakattu 708/331-8750
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	15,000	Currently in use	Federal
2	Gasoline - Regular	15,000	Currently in use	Federal
3	Gasoline - Regular	20,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

**Summary of Work**

The ball floats failed testing so replacing them with Overfill Drop Tubes for over fill protection. Removing balls only from all three tank as part of this process.

**Special Contingencies**

**Amendment Reason:**

Changing the Description as OSFM inspector

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

America Petropump Services LLC d/b/a Ampsco Services  
4075 Fox Valley Center Dr., Unit 9  
Aurora, IL 60504

Contact Person: Ravindra Penmatsa  
Phone: 312/286-6722  
Email: ravi@ampsco.net  
Contractor License # IL002420 Exp. 5/22/2027

Sincerely,

  
\_\_\_\_\_

Daniel Starks