



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047956
Permit #: 01395-2025ABN
Request Rec'd: 10/21/2025
Approval Date: 10/22/2025 SK
Permit Expires: 04/22/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Wheeling Development LLC 1910 S. Federal Street Chicago, IL 60616 Contact: Chen 312/799-9531	- name and address where tanks are located: Former Industrial 4737 S. Christiana Avenue Chicago, IL 60632 Cook County Contact: Chen 312/799-9531

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	5,000	Heating Oil	Inert material mixed with portland cement
2	5,000	Heating Oil	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Both USTs are suspected to run parallel with the building and within 2-4' from the foundation wall.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 708/308-8217 Email: admauro@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Sean Keane