



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2024605
Permit #: 01404-2025UPG
Request Rec'd: 10/22/2025
Approval Date: 10/22/2025 DS
Permit Expires: 04/22/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Schaumburg School District #54 524 East Schaumburg Road Schaumburg, IL 60194 Cook County Contact: Jason George 847/357-6855	FACILITY - name and address where tanks are located: Schaumburg School District #54 524 East Schaumburg Road Schaumburg, IL 60194 Cook County Contact: Jason George 847/357-6855
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	6,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	New

Summary of Work

IPT to be adding an Omntec Proteus K for the purpose of Inventory Monitoring.
The existing Pneumercator will monitor sensors, and the existing Incon Line Leak Monitor will continue to monitor Line Leak Detection.
There will be no changes to Leak Detection Monitoring at this time.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Interstate Pump and Tank, LLC 901 Niagara Street Waukesha, WI 531863817	Contact Person: Luke Garland Phone: 262/524-8494 Email: dan@interstatepumpandtank.com Contractor License # IL002423 Exp. 6/19/2027

Sincerely,

Daniel Starks