



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)

**FOR OFFICE USE ONLY**  
Facility #: 7039732  
Permit #: 01420-2025REM  
Request Rec'd: 10/24/2025  
Approval Date: 10/26/2025 DS  
Permit Expires: 04/28/2026

## **Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances**

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b>	<b>FACILITY</b>
- Corporation, partnership, or other business entity: Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821 White County Contact: Landon Bayley 618/382-2334Ext.248	- name and address where tanks are located: Hucks #349 201 East Main Street Mount Vernon, IL 62864 Jefferson County Contact: Norma McKay 618/382-2334

### **Tanks on the Permit For Piping Only**

<b>Tank #</b>	<b>Capacity</b>	<b>Product</b>	<b>Last Used Date</b>
1	15,000	Gasoline - Regular	
2	10,000	Gasoline - Regular	
3	10,000	Gasoline - Mid-grade	
4	4,000	B-11	
5	4,000	Kerosene	

### **Summary of Work**

Removing piping and existing STP sumps and UDC's. Replacing with all new sumps and OPW double wall piping.

### **Special Contingencies**

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: 812/425-4137 Email: <a href="mailto:mark.k@hci4.com">mark.k@hci4.com</a> Contractor License # IL646 Exp. 4/2/2026

Sincerely,

Daniel Starks