



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7039732
Permit #: 01422-2025UPG
Request Rec'd: 10/24/2025
Approval Date: 10/27/2025 DS
Permit Expires: 04/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS | FACILITY |
|---|--|
| - Corporation, partnership, or other business entity: Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821 White County Contact: Landon Bayley 618/382-2334Ext.248 | - name and address where tanks are located: Hucks #349 201 East Main Street Mount Vernon, IL 62864 Jefferson County Contact: Norma McKay 618/382-2334 |

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|---------------|----------------------|-----------------|--------------------|-------------------------|
| 1 | Gasoline - Regular | 15,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 3 | Gasoline - Mid-grade | 10,000 | Currently in use | Federal |
| 4 | B-11 | 4,000 | Currently in use | Federal |
| 5 | Kerosene | 4,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Omniplex II |
| Piping | Polyethylene Chase | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Omniflex II |
| Piping | Polyethylene Chase | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Omniflex II |
| Piping | Polyethylene Chase | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Omniflex II |
| Piping | Polyethylene Chase | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|--|---|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection | Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection |
| Piping | Flexible Double Wall OPW Flexworks | Replacing - Piping - Flexible Double Wall Total Containment Omniflex II |
| Piping | Polyethylene Chase | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 1/2 | Sump / Sensors Changing |
| 3/4 | Sump / Sensors Changing |
| 5/6 | Sump / Sensors Changing |
| 7/8 | Sump / Sensors Changing |
| 9/10 | Sump / Sensors Changing |
| 11/12 | Sump / Sensors Changing |
| 13/14 | Sump / Sensors Changing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 13/14 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Summary of Work

Remove all existing stp and dispenser sumps and replace with new. Run all new piping and conduits and add sump sensors with positive shutdown.

Special Contingencies**NOTE: Dispensers must be a full 10' to all buildings and property lines.****PERSON, FIRM OR COMPANY PERFORMING WORK:**

Hinderliter Construction & Maint., Inc.
3601 North St. Joseph Avenue
Evansville, IN 47720

Contact Person: Mark Hinderliter
Phone: 812/425-4137
Email: mark.k@hci4.com
Contractor License # IL646 Exp. 7/3/2026

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump | Removing |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump | Removing |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump | Removing |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump | Removing |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump | Removing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---------------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---------------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---------------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---------------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |

Dispenser 13/14 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|---------------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump | Removing |