



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY
Facility #: 2010041
Permit #: 00538-2025UPG
Request Rec'd: 05/05/2025
Approval Date: 05/05/2025 DS
Extension Date: 10/28/2025
Permit Expires: 05/05/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: River Grove Real Estate, Inc. 2474 Thatcher Road River Grove, IL 60171 Cook County Contact: Stephen Chacko 773/671-9864	FACILITY - name and address where tanks are located: River Grove Mart, Inc. 2474 Thatcher Road River Grove, IL 60171 Cook County Contact: Matthew Sonu 708/699-6805
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	12,000	Currently in use	Federal
4	Gasoline - Premium	12,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Gilbarco EMC with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root EMC with CSLD

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Gilbarco EMC with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root EMC with CSLD

Summary of Work

Removing existing tank monitor for building remodel. Reinstalling existing tank monitor after remodel completion.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

Daniel J. Starks

Daniel Starks