



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2032549
Permit #: 01432-2025UPG
Request Rec'd: 10/28/2025
Approval Date: 10/28/2025 DS
Permit Expires: 04/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 (None) County Contact: Bonnie Parrino 440/808-7268	FACILITY - name and address where tanks are located: Travel Center of America #30 16650 Russell Road Wadsworth, IL 60075 Lake County Contact: Ahmad Zaben 847/395-5580
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	10,000	Currently in use	Federal
7	Gasoline - Premium	10,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Beacon will replace the Single Wall Overspill Buckets with OPW Double-wall Overspill Buckets.

Special Contingencies

NOTE: Active N.O.V. must be complied at the time of this permitted work.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2027

Sincerely,

Daniel Starks