



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2035920
Permit #: 01443-2025UPG
Request Rec'd: 10/22/2025
Approval Date: 10/29/2025 DS
Permit Expires: 04/29/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Franklin Mobil, Inc. 3201 N. Mannheim Rd. Franklin Park, IL 60131 (None) County Contact: Sajjan Joseph 708/465-5984	FACILITY - name and address where tanks are located: RPN Petro, Inc. d/b/a O'Hare Mobil 3201 N. Mannheim Franklin Park, IL 60131 Cook County Contact: David Rajan 708/465-5984
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	15,000	Currently in use	Federal
2	Diesel Fuel	7,000	Currently in use	Federal
3	Gasoline - Premium	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
 Leak Detection - Piping	Sump Sensor	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
 Leak Detection - Piping	Sump Sensor	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing
11/12	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
 Leak Detection - Piping	Stand Alone Sump Sensor	Reusing Existing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
 Leak Detection - Piping	Stand Alone Sump Sensor	Reusing Existing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
 Leak Detection - Piping	Stand Alone Sump Sensor	Reusing Existing

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
🔌 Leak Detection - Piping	Stand Alone Sump Sensor	Reusing Existing

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
🔌 Leak Detection - Piping	Stand Alone Sump Sensor	Reusing Existing

Dispenser 11/12 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
🔌 Leak Detection - Piping	Stand Alone Sump Sensor	Reusing Existing

Summary of Work


TANK TOP UPGRADE INCLUDING SPILL BUCKETS. VENTS TO REMAIN.EXISTING LAY OUT WILL NOT CHANGE.

Special Contingencies

NOTE: A separate removal permit is needed for the old piping.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027

Sincerely,



Daniel Starks