



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2042122  
Permit #: 01408-2025UPG  
Request Rec'd: 10/13/2025  
Approval Date: 10/22/2025 SK  
Amended Date: 10/30/2025 SK  
Permit Expires: 04/22/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b>	<b>FACILITY</b>
- Corporation, partnership, or other business entity: West Town Mobil, Inc. 3942 W. Roosevelt Chicago, IL 60624 Cook County Contact: Abe Suliman 630/915-1834	- name and address where tanks are located: West Town Mobil, Inc. 3942 W. Roosevelt Rd. Chicago, IL 60624 Cook County Contact: Abe Suliman 630/915-1834

**Tanks on the Permit For Piping Only**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
3	E85	4,000	Currently in use	Federal

**Tank 3 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New

**Dispensers on the Permit**

<b>Dispenser</b>	<b>Action</b>
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing

**Dispenser 3/4 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 5/6 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Dispenser 9/10 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Summary of Work**

TAPPIUNTO EXISTING LCX LINE. RUNNING NEW LCX TO DISPENSERS 3/4-5/6-7/8-9/10. ADDING SENSORS WITH POSITIVE SHUT DOWN. DISNSER 1/2 WILL NOT BE DISTURBED.

**Special Contingencies****Amendment Reason:**

Change in piping type used.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027

Sincerely,

Sean Keane