



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2021150
Permit #: 01468-2025UPG
Request Rec'd: 11/03/2025
Approval Date: 11/03/2025 DS
Permit Expires: 05/05/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County Contact: Michele Alvarado 773/456-5280	FACILITY - name and address where tanks are located: Circle K #6772 1597 West Irving Park Road Hanover Park, IL 60103 Du Page County Contact: Joseph Thomas 630/372-0658
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	20,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Extractor Fitting Valves	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser - Vapor Riser	New
Piping	Other Steel Riser - Fill Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Regular Tank # 4 = All work being performed in the "Fill One Sump" Replace a manway cover that has a hole in it, Overspill bucket, Vapor bucket and Overfill drop tube. Installing (1) New Fill riser, (1) New Vapor riser, (1) New extractor fitting, and (1) New flex connector that has a hole in it for the vent line.

Special Contingencies

NOTE: The piping equipment, including the flex connector, is for the vent piping according to the contractor's notes.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel J. Starks

Daniel Starks