



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4007142
Permit #: 01473-2025UPG
Request Rec'd: 10/20/2025
Approval Date: 11/03/2025 DS
Permit Expires: 05/05/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Michele Alvarado 773/456-5280 | FACILITY - name and address where tanks are located: Circle K #1404 1212 North Bowman Danville, IL 61832 Vermilion County Contact: April Grimes 217/431-3750 |
|--|---|
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|---------------|--------------------|-----------------|--------------------|-------------------------|
| 4 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 6 | Gasoline - Premium | 12,000 | Currently in use | Federal |
| 7 | E85 | 4,000 | Currently in use | Federal |
| 8 | Diesel Fuel | 4,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Summary of Work

Replacing the current TLS-350 with CSLD to a new TLS-450 Plus with Cslid.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

JF Acquisition, LLC d/b/a Jones & Frank
100 Perimeter Park Drive Suite H
Morrisville, NC 275609203

Contact Person: Kevin Whritenour
Phone: 618/306-5098
Email: scot.russell@jfpetrogp.com
Contractor License # IL002422 Exp. 5/14/2026

Sincerely,



Daniel Starks