



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2027421  
Permit #: 01475-2025UPG  
Request Rec'd: 11/01/2025  
Approval Date: 11/04/2025 DS  
Permit Expires: 05/05/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                                                        |                                                                                                                                                                                                 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Casey's Retail Company<br>3305 SE Delaware Ave. P.O. Box 3004<br>Ankeny, IA 50021<br>Contact: Lee Lytle 515/446-6231 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Bucky's Express #6529<br>1304 Plainfield Road<br>Naperville, IL 60564<br>Du Page County<br>Contact: Stacey Oneal 515/446-6238 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1      | Gasoline - Regular | 6,000    | Currently in use | Federal          |
| 2      | Gasoline - Regular | 8,000    | Currently in use | Federal          |
| 3      | Gasoline - Regular | 8,000    | Currently in use | Federal          |
| 4      | Gasoline - Premium | 12,000   | Currently in use | Federal          |

**Tank 1 Equipment**

| Equipment Type          | Permit Equipment                                                   | Action                                                                        |
|-------------------------|--------------------------------------------------------------------|-------------------------------------------------------------------------------|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown         |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection                         | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |
| Leak Detection - Tank   | Automatic Tank Gauging Franklin Fueling Systems EVO 600            | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350   |

**Tank 2 Equipment**

| Equipment Type          | Permit Equipment                                        | Action                                                                        |
|-------------------------|---------------------------------------------------------|-------------------------------------------------------------------------------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection              | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |
| Leak Detection - Tank   | Automatic Tank Gauging Franklin Fueling Systems EVO 600 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350   |

### Tank 3 Equipment

| Equipment Type          | Permit Equipment                                        | Action                                                                        |
|-------------------------|---------------------------------------------------------|-------------------------------------------------------------------------------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection              | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |
| Leak Detection - Tank   | Automatic Tank Gauging Franklin Fueling Systems EVO 600 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350   |

### Tank 4 Equipment

| Equipment Type          | Permit Equipment                                        | Action                                                                        |
|-------------------------|---------------------------------------------------------|-------------------------------------------------------------------------------|
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection              | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection |
| Leak Detection - Tank   | Automatic Tank Gauging Franklin Fueling Systems EVO 600 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350   |

### Dispensers on the Permit

| Dispenser | Action                  |
|-----------|-------------------------|
| 1/2       | Sump / Sensors Changing |
| 3/4       | Sump / Sensors Changing |
| 5/6       | Sump / Sensors Changing |
| 7/8       | Sump / Sensors Changing |

### Dispenser 1/2 Equipment

| Equipment Type          | Permit Equipment                                              | Action                                                                |
|-------------------------|---------------------------------------------------------------|-----------------------------------------------------------------------|
| Leak Detection - Piping | Sump Sensor with positive shutdown<br>in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown |

### Dispenser 3/4 Equipment

| Equipment Type          | Permit Equipment                                              | Action                                                                |
|-------------------------|---------------------------------------------------------------|-----------------------------------------------------------------------|
| Leak Detection - Piping | Sump Sensor with positive shutdown<br>in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown |

### Dispenser 5/6 Equipment

| Equipment Type          | Permit Equipment                                              | Action                                                                |
|-------------------------|---------------------------------------------------------------|-----------------------------------------------------------------------|
| Leak Detection - Piping | Sump Sensor with positive shutdown<br>in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown |

### Dispenser 7/8 Equipment

| Equipment Type          | Permit Equipment                                              | Action                                                                |
|-------------------------|---------------------------------------------------------------|-----------------------------------------------------------------------|
| Leak Detection - Piping | Sump Sensor with positive shutdown<br>in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown |

### Summary of Work

Installing EVO 600 tank monitor with plld's, probes, and sump sensors for the tank sumps and dispenser sumps.

### Special Contingencies

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Metro Environmental Contractors, Inc. dba Metro Tank &  
Pump Company  
1111 West Dundee Road  
Wheeling, IL 600903936

Contact Person: Warren Cherner  
Phone: 847/465-4000  
Email: info@metrotank.com  
Contractor License # IL102 Exp. 9/20/2027

Sincerely,



---

Daniel Starks