

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2039726
Permit #: 01476-2025UPG
Request Rec'd: 11/04/2025
Approval Date:11/04/2025 DS
Permit Expires: 05/05/2026

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Brake Time IL Properties, LLC 6300 Richmond Avenue, Suite 300 Houston, TX 77057 (None) County

Contact: Omair Bashir 832/539-8190

FACILITY

- name and address where tanks are located:

Brake Time 20 E. Division Street Coal City, IL 60416 Grundy County

Contact: Muhammad Akhtar 832/539-8190

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	8,000	Currently in use	Federal
3	Diesel Fuel	12,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing double wall spill buckets on premium and diesel tanks and overfill droptube on premium tank

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

American Petroleum Solutions LLC 2911 Lund avenue apt 8 Rockford, IL 61109

Daniel J. Starke

Contact Person: Haibat Khan Phone: 909/312-9449

Email: apetro.office@gmail.com

Contractor License # IL002454 Exp. 5/21/2026

Sincerely,

Daniel Starks