



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 5000518
Permit #: 01480-2025UPG
Request Rec'd: 11/04/2025
Approval Date: 11/05/2025 DS
Permit Expires: 05/05/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Morgan County Highway Dept. 651 Brooklyn Ave PO Box 458 Jacksonville, IL 62651 Morgan County Contact: Matthew Coultas 217/243-8491	FACILITY - name and address where tanks are located: Morgan County Highway Dept 651 Brooklyn PO Box 458 Jacksonville, IL 62651 Morgan County Contact: Hance Calvin W 217/243-8491
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500

Summary of Work

REPLACING OPW TANK GAUGE WITH OMNTEC TANK GAUGE

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
W J Scott Company 3861 Tozer Road Springfield, IL 62707	Contact Person: Jim Scott Phone: 217/415-0345 Email: jimswjs@comcast.net Contractor License # IL1949 Exp. 4/18/2026

Sincerely,

Daniel Starks