



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
[www.sfm.illinois.gov](http://www.sfm.illinois.gov)  
[SFM.DPCS@illinois.gov](mailto:SFM.DPCS@illinois.gov)

**FOR OFFICE USE ONLY**  
Facility #: 2023094  
Permit #: 01481-2025UPG  
Request Rec'd: 11/05/2025  
Approval Date: 11/05/2025 DS  
Permit Expires: 05/05/2026

### **Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b>	<b>FACILITY</b>
- Corporation, partnership, or other business entity: IDN Sandhu Petro, Inc. 400 Silver Lake Rd. Cary, IL 60013 Henry County Contact: Bob Sandhu 847/639-4190	- name and address where tanks are located: Cary BP 400 Silver Lake Road Cary, IL 60013 McHenry County Contact: Jimmy Manget 847/639-4190

#### **Tanks on the Permit**

<b>Tank #</b>	<b>Product</b>	<b>Capacity</b>	<b>Tank Status</b>	<b>Regulated Status</b>
3	Gasoline - Regular	6,000	Currently in use	Federal
4	Gasoline - Regular	6,000	Currently in use	Federal

#### **Tank 3 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 30MV

#### **Tank 4 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 30MV

#### **Summary of Work**

Disabling ball floats and installing new 71SO overfill drop tubes set at 94%

#### **Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Big Daddy Pump & Compliance, Inc. 301 Main St Unit 105 Antioch, IL 60073	Contact Person: Billy Umphrey Phone: 352/901-4467 Email: <a href="mailto:billy@bigdaddypump.com">billy@bigdaddypump.com</a> Contractor License # IL002457 Exp. 12/2/2026

Sincerely,

Daniel Starks