

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 6023990
Permit #: 00804-2025UPG
Request Rec'd: 06/27/2025
Approval Date: 06/27/2025 DS
Amended Date:11/06/2025 DS
Permit Expires: 12/29/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County

Contact: Michele Alvarado 773/456-5280

**FACILITY** 

- name and address where tanks are located:

Circle K #1599 629 West Schwarz Edwardsville, IL 62025 Madison County

Contact: Shelly Fink 812/379-9227

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal

### Tank 1 Equipment

Equipment Type	Permit Equipment	Action	
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve	
Piping	Other Steel Riser	New	
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket	

#### **Special Contingencies**

#### **Amendment Reason:**

Janiel J. Starke

amend permit to remove all of tank 2 as it is under another permit already

PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: 314/772-4501
Email: testing@neumayerequipment.com
Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel Starks