



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2000995
Permit #: 01515-2025UPG
Request Rec'd: 11/11/2025
Approval Date: 11/12/2025 DS
Permit Expires: 05/12/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ozinga Bros., Inc, 19001 Old LaGrange Road Mokena, IL 60448 Cook County Contact: Michael Saldarelli 312/656-8393	FACILITY - name and address where tanks are located: Ozinga Bros., Inc. 200 West Jarvis Avenue Des Plaines, IL 600181952 Cook County Contact: Richard Slager 312/656-8393
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Dyed Diesel	10,000	Currently in use	Federal
12	Diesel Fuel	20,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Remove existing tank sumps, spill buckets, and all associated materials on top of two (2) tanks. Furnish and install new tank sumps, submersible pumps, veeder root probes, and spill buckets/drop tubes on both tanks. Tank sumps to have lids to prevent future water ingress.

Special Contingencies

NOTE: Contractor chose "yes" that the risers or vents were repaired due to water ingress, but I don't see where the work on this permit would support that. I believe it was a mistake.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Superior Petroleum Marketers, Inc.
2336 Albright Lane P. O.Box 4648
Wheaton, IL 601894648

Contact Person: Steve Tuttle
Phone: 630/588-1198
Email: tuttle.steve11@gmail.com
Contractor License # IL2087 Exp. 2/4/2026

Sincerely,



Daniel Starks