



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 1037092
Permit #: 01522-2025UPG
Request Rec'd: 11/12/2025
Approval Date: 11/12/2025 DS
Permit Expires: 05/12/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS - Corporation, partnership, or other business entity: | FACILITY - name and address where tanks are located: |
|--|--|
| Estes Terminals, LLC 3901 W. Broad Street Richmond, VA 23230 (None) County Contact: Ruben Byerley 804/353-1900Ext.2263 | Estes Express Lines 1751 New Milford School Road Rockford, IL 61109 Winnebago County Contact: Ruben Byerley 804/337-1197 |

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|---------------|----------------|-----------------|--------------------|-------------------------|
| 1 | Diesel Fuel | 20,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Summary of Work

Replacing Existing TLS350 console with a TLS450 plus. All other existing Veeder Root equipment is being re-used

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026 |

Sincerely,

Daniel Starks