



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2046069
Permit #:	01523-2025UPG
Request Rec'd:	11/12/2025
Approval Date:	11/12/2025 DS
Permit Expires:	05/12/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Contact: Maggie Sebaugh 502/572-1259	FACILITY - name and address where tanks are located: Thornton's #320 476 York Rd. Elmhurst, IL 60126 Du Page County Contact: Lisa Sayeh 502/425-8022
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal
2	E85	6,000	Currently in use	Federal
3	Diesel Fuel	10,000	Currently in use	Federal
4	Gasoline - Premium	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	New

Summary of Work

Remove existing TLS 350 & install TLS450+. Existing probes & sensors to remain

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 815/398-6250
Email: amberp@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks