



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2009891
Permit #: 01535-2025UPG
Request Rec'd: 11/13/2025
Approval Date: 11/13/2025 DS
Permit Expires: 05/13/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sasam, Inc. 1204 N. Elmhurst Rd. Prospect Heights, IL 60070 Cook County Contact: Kamran Moten 773/981-7460	FACILITY - name and address where tanks are located: Citgo 1204 Elmhurst Road Prospect Heights, IL 60070 Cook County Contact: Kamran Moten 773/981-7460
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	12,000	Currently in use	Federal
4	Gasoline - Premium	12,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing Failed single wall spill containers with EMCO double wall spill container.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
American Petroleum Solutions LLC 2911 Lund avenue apt 8 Rockford, IL 61109	Contact Person: Haibat Khan Phone: 909/312-9449 Email: apetro.office@gmail.com Contractor License # IL002454 Exp. 5/21/2026

Sincerely,

Daniel Starks