



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2045957
Permit #: 01543-2025UPG
Request Rec'd: 11/10/2025
Approval Date: 11/17/2025 DS
Permit Expires: 05/19/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: TA Operating, LLC 24601 Center Ridge Road Suite 200 Westlake, OH 44145 Contact: Katie Wells 440/808-3296	FACILITY - name and address where tanks are located: Petro Stopping Center 24225 W.Lorenzo Road Wilmington, IL 60481 Will County Contact: Lucy Shields 770/367-8179
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	8,000	Currently in use	Federal
2	Gasoline - Regular	30,000	Currently in use	Federal
3	Diesel Fuel	30,000	Currently in use	Federal
4	Diesel Fuel	30,000	Currently in use	Federal
5	Diesel Fuel	30,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Required Other Veeder Root TLS 450 Plus Monitor only for sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor


Summary of Work

Install new Veeder Root TLS 450 Plus.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 600903936	Contact Person: Warren Cherner Phone: 847/465-4000 Email: info@metrotank.com Contractor License # IL102 Exp. 9/20/2027

Sincerely,



Daniel Starks