



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2023371
Permit #: 01556-2025UPG
Request Rec'd: 11/18/2025
Approval Date: 11/19/2025 DS
Permit Expires: 05/19/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Amirali Sayani 1100 Chetwood Drive Carol Stream, IL 60188 Du Page County Contact: Amirali Sayani 630/417-9200	FACILITY - name and address where tanks are located: West Chicago Citgo 250 S. Neltnor Blvd. West Chicago, IL 60185 Du Page County Contact: Anil Sayani 630/293-1242
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve OPW 53	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve OPW 53	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing the Regular and Premium tanks' single wall spill buckets with double wall spill buckets. Ball floats were removed from Regular and Premium

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

Daniel J. Starks

Daniel Starks